



# Water Underfloor Heating Kit

- ✓ For multiple rooms
- ✓ 50 year pipe warranty
- ✓ CE approved
- ✓ Easy to install

INSTALLATION MANUAL



## UNDERFLOOR HEATING SYSTEM

MULTIPLE ROOM SYSTEM INSTALLATION MANUAL

Manufactured in  
Europe!



## Thank you for investing in our industry leading ProWarm™ underfloor heating system

ProWarm™ Water Underfloor Heating Systems are the ideal choice for homeowners and tradesmen wishing to install a premium branded water underfloor heating kit.

This instruction manual contains important information regarding the safe installation and operation of your underfloor heating system. Please read carefully.

### See our online videos for helpful guidance

In addition to this manual we have online installation videos that guide you through each stage of process with easy to follow CGI graphics and helpful dialogue. [Scan QR code to watch video >](#)



Technical support **01268 567019**

## Before you begin Installing:

Please read through these instructions carefully and check that you have all the components required. ProWarm™ water underfloor heating kits contain everything you need in one box for your water underfloor heating project. NB: This multi zone system is controlled by multiple thermostats.

- ✓ A rated UPS 2 Grundfos pump
- ✓ PE-Xb-multilayer pipe to suit area
- ✓ Edging insulation (NA: for low profile)
- ✓ Manual Thermostat
- ✓ Actuators
- ✓ Pipe Staples
- ✓ Pipe Cutters
- ✓ Pipe rerounding tool
- ✓ Wiring centre
- ✓ All pipe connections to fix pipe to pump and manifold




We use **high quality multi layered pipe** (PE-Xb-AI-HDPE) in all our ProWarm™ water underfloor heating systems

**AN INNER LAYER** in cross-linked polyethylene PE-Xb (crosslinked with silanes)

**AN INTERMEDIATE LAYER** in aluminium alloy, butt-welded along length of pipe.

**50 YEAR PIPE WARRANTY**



- ✓ PE-Xb-AI-HDPE.
- ✓ Working pressure & temperature 10bar, 95°C.
- ✓ 100% oxygen impermeable.
- ✓ Lifetime warranty.



**TWO BINDING LAYERS** of adhesive bind the metal pipe with the two outer layers in cross-linked polyethylene

**AN OUTER LAYER** in cross-linked polyethylene PE-Xb-AI-HDPE (crosslinked with silanes).

# Installation for a **multiple room (multi circuit system)**



- 1) Select a suitable location for the pump & manifold unit and mount on the wall. See opposite page for assembly.
- 2) Refer to the typical pipe installation drawings and determine the pipe layout - the layout is not critical and can be varied to suit site conditions, the important criteria being the pipe spacing, see below.
- 4) The pipe is marked every metre by the metre. (maximum length for any circuit is 110m, 70m for low profile 12mm pipe circuit).
- 5) Pipes should be laid 100mm away from walls.
- 6) Do not lay pipe under fixed units.
- 7) Lay the rooms furthest from the manifold and work back, do the room with the manifold last.
- 8) When pipes to/from one area pass through another area, the two pipes should be run together, the 'bunches' of pipes should then be spaced as if they were one pipe.
- 9) Lay the pipe as planned, fixing every 1.0m if on a screeded celotex base and return to the manifold.
- 10) If the pipe is kinked when bending, the pipe should be straightened and rearranged so that the location of the kink remains in a straight length, no other remedial action is required.

## PIPE SPACINGS

**LOW PROFILE SYSTEM** panels are spaced at 150mm centres

**STANDARD OUTPUT SYSTEM** suitable for internal well insulated areas such as a living room, kitchen or bathroom. **Pipe spacings are set at 250mm centres.**


**HIGH OUTPUT SYSTEM** suitable for areas of high heat loss, ideal for conservatories, extensions and external buildings. **Pipe spacings are set at 200mm centres.**

11) To lay the circuit, cut the pipe end squarely using the plastic pipe cutter, re-round the pipe end with the tool provided, place the nut over the pipe, ensure the olive and insert is fully fitted over the end of the pipe and the assembly is attached to the manifold. Tighten the nut using an open end spanner. Do not over tighten.

12) Note also the room to which each circuit applies.

13) Prevent people from walking on the pipes, keep tools etc away from the pipes and use running boards. The pipe is very tough, but it is better to be safe than sorry.

## PUMP & MANIFOLD ASSEMBLY



- 1) Attach manifold to wall.
- 2) Fit ball valves to manifold, the end with the loose nut to manifold( remember the washers!).
- 3) Assemble pump & mixing valve as shown.
- 4) Connect supply pipework to mixing valve using  $\frac{3}{4}$ " male iron compression fittings.  
**DO NOT APPLY HEAT TO MIXING VALVE**

## FILLING THE MANIFOLD SYSTEM

- 1) It is **IMPORTANT** that the underfloor heating system is properly filled with water and purged completely of air to ensure correct operation, it is therefore necessary to follow the procedure below.
- 2) **IT IS NOT ADEQUATE TO FILL THE SYSTEM USING THE BOILER FILLING LOOP!**
- 3) Connect a hose from a mains pressure cold water supply to the hose connection on the top (flow) manifold, and another hose from the hose connection on the bottom (return) manifold to a drain.
- 4) Ensure that all the black caps on the bottom (return) manifold are screwed down, closing the valves.

## FILLING THE MANIFOLD SYSTEM (cont.)

- 5) Ensure that the main flow & return ball valves are closed on the manifold.
- 6) Turn on the water and open the hose connection valve on the top (flow) manifold.
- 7) Open the first circuit valve by unscrewing the black cap allowing water to flow into the pipe.
- 8) Open the hose connection valve on the bottom (return manifold) allowing water to flow freely into the drain until the water is clear with no air bubbles.
- 9) Open the second circuit valve (black cap) and close the first.
- 10) Open the third circuit valve and close the second etc.
- 11) Continue until the last circuit has been purged and close the hose connection valve on the bottom (return) manifold before closing the last circuit valve (black cap).
- 12) While under pressure, check manifold & pipework for leakage.
- 13) Close hose connection valve on the top (flow manifold) and remove the hoses.
- 14) If possible pressure test the system to 6 bar for 2 hours.

## COMMISSIONING


- 1) Screed or chipboard flooring should be laid immediately after pipelaying to protect the pipe.
- 2) Concrete screed floors must be cured before any heat is applied, a general rule of thumb is to allow 1 day per 2 millimetres of screed.
- 3) Timber floor with drymix infill can have heat applied immediately, the drymix must be dried completely before laying the flooring.
- 4) Hardwood timber flooring must be 'conditioned' before fixing.
- 5) It is important to purge the pipework from the boiler to the manifold, to avoid air being introduced into the underfloor heating system.
- 6) It is not normally necessary to balance the system but if required follow this procedure. The system is balanced by running the pump, and adjusting the flow to each zone by turning the square spigots under the blue caps on the bottom manifold, the flow in the respective sight glasses should be set at a figure calculated by dividing the length of pipe for that zone by 40. Example: Circuit 1,  $85\text{m} \div 40 = \text{approx } 2$  on the scale. Low profile systems circuit at  $70\text{m} \div 40 = 1.75$ .
- 7) Initially start the system with the thermostatic valve set at min (35°C).
- 8) Increase the setting by 5° per day, up to a maximum of 50° for concrete floors, max 65° for timber floors.
- 8) Fit actuators to valves after connecting the control wiring.
- 9) It is important that the actuators are screwed tightly on to the valve.
- 9) The flow & return from the boiler should be connected to the manifold connections shown using compression couplings.
- 10) NOTE. When first starting up the system it may take 12-24 hours for the heating effect to become apparent!



## MAINTENANCE **It is recommended that the following maintenance be carried out annually.**

- 1)** Check that all actuator nuts are tightened firmly and that actuators are not loose. **2)** Remove end plug from pump and check that pump rotates when energised. **3)** Turn up thermostats and check that actuators move into open position also check flow gauges are indicating. If not, re-pressurise manifold, remove indicator, clean and replace, repressurise manifold.

# Electrical setup


- 1) Wiring from thermostats to manifold wiring centre should be 1mm 3core + earth (6243Y).  
NB: A network system must be wired in 'CAT6' cable.
- 2) The wiring centre has a back entry to avoid surface wiring.
- 3) Where one room has more than one pipe circuit it will be necessary to connect all the circuit actuators to that particular zone on the controller, controlled by one thermostat.
- 4) Thermostat position in the room is not critical but positions affected by the sun should be avoided, mounting height approx 1.5M








### Schematic for system boiler & UFH + radiators + hot water



### Schematic for gas combination boiler & underfloor heating + radiators



# Typical fixing methods

## UNDER NEW CONCRETE OR SCREED FLOORS

**A cost effective solution for installing water underfloor heating into new build properties or new extensions.**

This type of system installation is the most popular and cost effective type on the market today, the pipes are incased in screed or concrete meaning that the whole floor warms up like one huge storage radiator. This system is normally for new build houses or extensions/conservatories.

## CLIP RAIL SYSTEM



## BETWEEN JOISTS OR SUSPENDED FLOORS

**Installing water underfloor heating between joists is easy using our different installation solutions.**

Please note all in joist systems require the pipe spacing to be 200mm apart or less

This means you need to select a conservatory style kit or a multiple room kit – standard room kits are designed with the pipe spacing at 250mm centers which would mean you would not have enough pipe in the kit

## SPREADER PLATE SYSTEM




## OVER EXISTING FLOORS

**Installing water underfloor heating over existing floors is simple using our different installation solutions.**

Our overfloor systems can be installed directly over any solid subfloor such as existing floorboards, plywood or concrete/ screed floors, or any solid surface such as existing tiles/ wooden floors.


## FLOATING FLOOR PANELS for finished timber floor




### PLASTIC EGG CRATE SYSTEM



### CLIPPED DIRECT WITH STAPLES



### DRY BISCUIT MIX/ SCREED SYSTEM



### IN JOIST FOIL BOARDS



### SOLID FLOOR PANELS for finished tiled floor



For more information on various floor fixings watch our helpful videos for step by step guidance.

Scan QR code to watch videos >





Visit us online for a list of suppliers:  
**[www.prowarm.com](http://www.prowarm.com)**



Call us direct for technical advice:  
**01268 567019**



Unit 12, Carnival Park, Carnival Way, Basildon, Essex, SS14 3WN

**T: 01268 567019**

**[www.prowarm.com](http://www.prowarm.com)**



Gas Safe registration  
number: 640068